



**NASSAU HEALTH CARE CORPORATION**  
**NASSAU UNIVERSITY MEDICAL CENTER**  
**2201 Hempstead Turnpike**  
**East Meadow, New York 11554**  
**(516) 572-0123**

**Q & A**

**NUMC Formal Sealed Bid Proposal # MC42-11303-5392**

**INSPECTION, MAINTENANCE, RECHARGING, HYDROTESTING, TAGGING AND NEW REPLACEMENT OF FIRE EXTINGUISHERS**

See RFI responses below in red:

1. Item #3 Service Charge Tagging- Is this price in addition to any work needed or added to annual maintenance inspection? **Add to the annual maintenance inspection**
2. Item #24- Refill Halon or Halotron fire extinguishers? **Halon**
3. Item #47- Please define DCP? **it's DCB main building on campus**
4. Item # 56- Recharge 20lb Gas Tanks- Are these CO2 cylinders? **20lb are dry chemical suppression system**
5. Item #63-Does this contract include inspection of fire hose? **No fire hose**
6. Item # 67- What are the 2-inch split "O" rings for? **2" O Ring goes between the handle and extinguisher to prevent leaks**
7. Item #75- Any Extinguisher that fails inspection shall be replaced by new extinguishers. - Does this also include any fire extinguisher that could be repaired? **Any extinguisher that fails gets replaced from our spare's**
8. Does this contract also include monthly inspections to be performed at all your locations by the company who is awarded the contract? **Yes, this contract includes all locations monthly**
9. Item #47 -THIS ITEM STATES 3" DOUBLE SEAL GASKET FOR 20LB DCP. DEFINE DCP? **DCP stands for Dry Chemical Power**
10. Item # 56- WHAT BRAND FIRE SYSTEM? **Brand Name is Buckeye**
11. Item # 67- 2" "O" RINGS SEEM TOO LARGE FOR PORTABLE FIRE EXTINGUISHERS ARE THESE FOR THE SUPPRESSION SYSTEM? **2" O'Ring is for 20lb dry power system**